



Aqualine Water Treatment Products Inc.

710 Northeast Dr. Suite 10

Davidson, NC. 28036

Tel 704 895 5500 - Fax 704 895 5501

24-Hour Emergency Response Number: 704-580-5511

<mailto:jsgroi@aqualine.net>

<http://www.aqualine.net>

Client: **Example Service Report**

Date:

Contact:

Address:

COMMENTS/RECOMMENDATIONS FOR CLIENT:

	MakeUp	CT	Chill	Hot	Process	
pH		8.1	9.9	10.2		
Conductivity		665	2130	1985		
TDS		447	1512	1325		
ORP		260				
Temp		72	79.2	145.3		
Clarity		Clear	Clear	Clear		
MO		0.65				
NO2			550	850		
F Cl		0.63				
T Cl		0.87				
Fe		0.18	0.05	0.11		
Cu		0.04	<0.01	0.03		
Zinc						
ATP:	Total	Free	Controller		Meter	Mo. Water Use
	90	55	CT Make Up	130,000	598,000	49,500
			CT Bleed Line	8,900	53,000	
PM Procedures:						
Cleaned probes, etc		y				
Primed pumps		y				
Checked calibration		y				
Products:	System					Order
	4800	45				
	4114	30				
	4115	35				

Cooling Tower System

- > Replenished chemical containment levels
- > Increased 4800 feed pump stroke 5%
- > Injector valve for 4114 clogged. Valve was cleaned thoroughly
- > Flow switch, pH probe, and conductivity probe cleaned; calibration good
- > Bacterial analysis and ATP results indicate excellent microbial control
- > All chemical levels o.k. as tested

Chill Water System

- > Filter Bag Replaced
- > All chemical levels o.k. as tested

Hot Water System

- > Added 5 lbs of inhibitor to keep nitrite levels in middle of control range
- > All chemical levels o.k. as tested